

This Water Quality report is provided in accordance with the Safe Drinking Water Act (SDWA) and designed to inform you of the quality of water provided to our customers last year.

How might I become actively involved?

If you would like to become involved or observe the decision-making process that affect drinking water quality or if you have any further questions about this drinking water report, please call us at 816-630-0755 ext. 227 to inquire about scheduled meetings or contact persons.

Tour our Facilities: Public and educational tours of the Water Treatment Plant may be arranged by calling 816-630-0755 ext. 227.

Who regulates our water utility? The Missouri Department of Natural Resources regulates our water system and requires us to test our water on a regular basis to ensure its safety. Our system has been assigned the identification number MO1010261 for the purposes of tracking test results. Last year we tested for a variety of contaminants. The detectable results of these tests are on the following pages of this report. The Excelsior Springs Water Department has never had any monitoring or treatment violations, and takes pride in providing the highest quality of treated water to our consumers.

What is the source of our water? The sources of drinking water, both tap water and bottled water, include rivers, lakes, streams, ponds, reservoirs, springs, and groundwater wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Excelsior Springs' water comes from six (6) municipal wells in the Missouri River alluvial field. The wells range from 78 to 110 feet deep and are located seven miles south of the City Limits on "N" Highway.

Source Water Assessment: The Department of Natural Resources conducted a source water assessment to determine the susceptibility of our water source to potential contaminants. This process involved the establishment of source water area delineations for each well or surface water intake and then a contaminant inventory was performed within those delineated areas to assess potential threats to each source. Assessment maps and summary information sheets are available on the internet at <http://maproom.missouri.edu/swipmaps/pwssid.htm>. To access the maps for your water system you will need the State-assigned identification code, which is printed at the top of this report. The Source Water Inventory Project maps and information sheets provide a foundation upon which a more comprehensive source water protection plan can be developed.

Health precautions: Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791). **Contaminants that may be present in source water include:**

- * Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- * Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.
- * Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- * Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- * Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the Department of Natural Resources prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Department of Health regulations, establish limits for contaminants in bottled water which must provide the same protection for public health.

Do you need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Excelsior Springs
2011 Annual Water Quality Report
(Consumer Confidence Report)
Contaminants Report

MO1010261

Definitions:

MCLG: Maximum Contaminant Level Goal, or the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL: Maximum Contaminant Level, or the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

AL: Action Level, or the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow..

TT: Treatment Technique, or a required process intended to reduce the level of a contaminant in drinking water.

90th percentile: For lead and Copper testing. 10% of test results are above this level and 90% are below this level.

Level Found: is the average of all test results for a particular contaminant.

Range of Detections: Shows the lowest and highest levels found during a testing period, if only one sample was taken, then this number equals the Level Found.

MRLDG: Maximum Residual Disinfectant Level Goal, or the level of a drinking water disinfectant below which there is no known or expected risk to health.

MRDL: Maximum Residual Disinfectant Level, or the highest level of a disinfectant allowed in drinking water.

RAA: Running Annual Average, or the average of sample analytical results for samples taken during the previous four calendar quarters.

Abbreviations:

PPB: parts per billion or micrograms per liter.

ppm: parts per million or milligrams per liter.

n/a: not applicable.

NTU: Nephelometric Turbidity Unit, used to measure cloudiness in drinking water.

MFL: million fibers per liter, used to measure asbestos concentration.

nd: not detectable at testing limits.

The state has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Records with a sample year more than one year old are still considered representative.

Regulated Contaminants

Regulated Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
BARIUM	3/7/2011	0.146	0.146	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
CHROMIUM	3/7/2011	1.78	1.78	ppb	100	100	Discharge from steel and pulp mills
FLUORIDE	3/7/2011	0.15	0.15	ppm	4	4	Natural deposits; Water additive which promotes strong teeth

Disinfection Byproducts	Monitoring Period	RAA	Range	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	2011	29	18.2 - 33.2	ppb	60	0	Byproduct of drinking water disinfection
TTHM	2011	60	46.4 - 73.6	ppb	80	0	Byproduct of drinking water disinfection

Lead and Copper	Date	90 TH Percentile	Range	Unit	AL	Sites Over AL	Typical Source
-----------------	------	-----------------------------	-------	------	----	---------------	----------------

Friday, June 08, 2012

Excelsior Springs
2011 Annual Water Quality Report
(Consumer Confidence Report)

MO1010261

COPPER	2011 - 2013	0.0884	0.0114 - 0.175	ppm	1.3	0	Corrosion of household plumbing systems
LEAD	2011 - 2013	1.44	1.24 - 2.13	ppb	15	0	Corrosion of household plumbing systems

Microbiological	Result	MCL	MCLG	Typical Source
No Detected Results were Found in the Calendar Year of 2011				

Violations and Health Effects Information

During the 2011 calendar year, we had the below noted violation(s) of drinking water regulations.

Type	Category	Analyte	Compliance Period
No Violations Occurred in the Calendar Year of 2011			

Optional Monitoring (not required by EPA)

Optional Contaminants

Monitoring is not required for optional contaminants.

Secondary Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG
ALKALINITY, CaCO ₃ STABILITY	3/7/2011	149	149	MG/L		
CALCIUM	3/7/2011	27.4	27.4	MG/L		
CHLORIDE	3/7/2011	14.6	14.6	MG/L	250	
HARDNESS, CARBONATE	3/7/2011	157	157	MG/L		
IRON	3/7/2011	0.0277	0.0277	MG/L	0.3	
MAGNESIUM	3/7/2011	21.5	21.5	MG/L		
MANGANESE	3/7/2011	0.00161	0.00161	MG/L	0.05	
PH	3/7/2011	7.95	7.95	PH	8.5	
POTASSIUM	3/7/2011	5.51	5.51	MG/L		
SODIUM	3/7/2011	7.39	7.39	MG/L		20
SULFATE	3/7/2011	35.6	35.6	MG/L	250	
TDS	3/7/2011	193	193	MG/L	500	

Special Lead and Copper Notice:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Excelsior Springs is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (800-426-4791) or at <http://water.epa.gov/drink/info/lead/index.cfm>.